4646377506

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Brewer Realty DATE 5-4-79 PERMIT NO. 128

PHONE: Business _____ Home _____

LOCATION 150 W to Lon 1103 to Lon 1190

_____ S. R. No. _____

SUBDIVISION NAME Idlewood Harbor LOT NO. 89 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area ½ acre

Character & Porosity of Soil Clay loamy
Percolation Rate 60 min/in
Topography 5 to 10 % slope
Depth to Water Table 10+
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 10-
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Gibson

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 5-4-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold