## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Brewer Realty DATE 5-4-79 PERMIT NO. 128

PHONE: Business _____ Home _____

LOCATION 150 ft E on 109 TL on 1190

S. R. No. _____

SUBDIVISION NAME Elmwood Harbor LOT NO. 89 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes | (✓) | No | ( ) |
| Auto. Dishwasher | Yes | (✓) | No | ( ) |
| Auto. Wash. Machine | Yes | (✓) | No | ( ) |
| Site Suitable | Yes | (✓) | No | ( ) |

Lot Area ½ Acre

Character & Porosity of Soil Clay Loam
Percolation Rate 60 min/in
Topography 5 to 10 % S/S
Depth to Water Table 10 ft
Rock or other impervious formations None




Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 20"
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Wilson

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Thomas Lowe DATE 5-4-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold