4646382563

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Garland Hudgens DATE 7-27-79 PERMIT NO. 257

PHONE: Business _____ Home _____

LOCATION 150W TL on 1109 TR on 1190


S. R. No. _____

SUBDIVISION NAME Idlewood Harbor LOT NO. 53 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	—	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	sink.	
Lot Area ½ AC.			Rock or other impervious formations	none obs.	



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Wayne Dobson

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 7-27-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold