DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: C W Brown — APPLICANT: ___
ADDRESS: ___ — APPLICATION DATE: ___ — DATE EVALUATED: ___
PROPOSED FACILITY: 3BD - 2BA — PROPOSED DESIGN FLOW (.1949): ___ — PROPERTY SIZE: ___
LOCATION OF SITE: Moreland Dr - Lot 84 Idlewood Harbor — PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	T	0-9	sbk scl						.28
		10-21	sbk cl						
		22-39	wk sbk hcl	FI S P					
		40-47	wk sbk c	FI S P					
2	CCT	0-10	sbk scl	FR S SP					.3
		11-17	sbk cl	FI S P					
		18-28	wk sbk hcl	FI S P					
		29-33	wk sbk c	FI S P					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___