IREDELL COUNTY HEALTH DEPARTMENT

APPENDIX H

SITE EVALUATION

(Ground Absorption Sewage Disposal)

OWNER: C.W. Brewer DATE REQUESTED: 7-11-80

ADDRESS: Iredell PLAT NO.: 4480 Tallwood Harbor

COUNTY: Iredell LOT SIZE: See book

LOCATION OF SITE: I-40 W TL 1169 TR 1190 TL 1290 pass 1291 TR next street 2nd on R

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-6%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 clay)	S (PS) U clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey soils)	S (PS) U Sub Angular Blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) PS 48" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, rock)	(S) PS U None Observed	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) PS U No Mottles	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	(S) (PS) U Ompi	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION*	PS			
SOIL SERIES	Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.)

Recommendations/Comments: Keep 50' minimum from Sewage System on lot #82

Described By: FAC

Title: S-T Date: 7-11-80

DHS Form 2601 (2/77)
Sanitation