4646392084

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Smith Builders DATE 1-11-79 PERMIT NO. 14

PHONE: Business _____ Home _____

LOCATION 1109 + R on 1190

S. R. No. _____

SUBDIVISION NAME Idlewood Harbor LOT NO. 48 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 1/2 ac

Character & Porosity of Soil Clay loam
Percolation Rate 80 min/in
Topography 2% slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10+
Water Supply: Individual (✓)
Public ( )

Installed by T.R. Bowles

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water coming in on left 30' of main line

CERTIFICATE OF COMPLETION BY Steve Houston DATE 1-11-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold