IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 167869 PIN # 4646 41 4501 DATE 7-25-11

OWNER Jim Eglahan APPLICANT: same PHONE: Home/Cell # 704-231-2917 Business #

SITE ADDRESS 121 Knox Haven Lane OWNER / APPLICANT ADDRESS

SITE DIRECTIONS 21 S TL Alcove TR Catalina TL Knox Haven on left at end of cul-de-sac

SUBDIVISION Knox Haven BLOCK / SECTION LOT # 4 LOT AREA DESIGN FLOW 480 gpd L.T.A.R.

Septic Tank Existing Gallons: STB Date

Pump Tank Existing Gallons: P T Date

Pump Make Model Serial #

No. Nitrification Fields: No. Lines Linear Feet

Trench Width Max. Trench Bottom Depth Gravel Depth

☐ New System ☐ Repair ☐ Expansion System Type I II III (IV) V VI

System Description: Existing LP Panel

Repair System Description: LP 25% Reduction or Panel

Maintenance Agreement Required ☒ YES ☐ NO

☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions

Pool shall be min. 15' from septic system Repair Area

INITIAL SITE SKETCH

AS BUILT SKETCH

See surveyed plan from Rollans Soil & Env. Services showing pool and revised Repair Area

Earth dams shall be installed at the beginning and end of each Repair lateral

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration* ☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* *site plan valid 60 mo.* ☐ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Date 7/26/2011 Installed by:

IMPROVEMENT PERMIT by: ***REHS*** Date OPERATION PERMIT by: ***REHS*** Date

AUTHORIZATION TO CONSTRUCT by: ***REHS*** Date Existing System Inspected by: Judy Melville ***REHS*** Date 7-25-11

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant