COPY

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 141676 PIN # 4646414698 DATE July 28, 2010

OWNER or APPLICANT Dumitru (Wesley) Zdrentan PHONE: Business Home: 704-658-5106

OWNER or APPLICANT ADDRESS 406 Canvasback Rd. Mooresville NC 28117

LOCATION / DIRECTIONS Williamson Rd S. TR Alcove TR Catalina TL Knox Haven on left before cul-de-sac

SUBDIVISION Knox Haven BLOCK / SECTION LOT # 2 LOT AREA DESIGN FLOW 480gpd L.T.A.R. .3gpd/ft²

Septic Tank 1000 Gallons: STB 875 Date 11-25-10

Pump Tank Gallons: PT Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 5 Linear Feet 416'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI

System Description: 25% Reduction Gravity

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons 8

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☒ Public ☐ Community

Comments / Conditions

Shave berm in system area

BERM SHAVED JA

Comments / Conditions

INITIAL SITE SKETCH

See Approved Plan from Rowans Soil & Environmental Services

AS BUILT SKETCH

INSTALLED AS SHOWN ON PLAN JA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 7/29/10

Improvement Permit by: Date 7-28-10

Authorization to Construct by: Date 7-29-10

Installed by: ROWAN

Operation Permit by: REHS Date: 7-28-11

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant