IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jarry Lawing DATE 10-23-74 PERMIT NO. 305

PHONE: Business _____ Home _____

LOCATION US 21 South cross I-77 on 1109 next turn left into Bonanza S. R. No. _____

SUBDIVISION NAME Bonanza LOT NO. 2 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area Large

Character & Porosity of Soil Fine Sandy Clayloam Porosity Good
Percolation Rate Not taken
Topography 20% slope
Depth to Water Table 6 to 8' to lake level
Rock or other impervious formations large rock formation in front so had to install system behind house



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 630 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: Grade + fill area over lines so that surface water drains off and there is at least 12" of cover.

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 10-23-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold