IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eddie Blythe DATE 8-14-74 PERMIT NO. 215

PHONE: Business _____ Home 392-9625

LOCATION 1109 Turn into Bonanza

SUBDIVISION NAME Bonanza S. R. No. _____

LOT NO. 9 SECTION OR BLOCK NO. 2

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3+ acres


Character & Porosity of Soil Fine Sandy Clay loam Porosity Fair

Percolation Rate 2/5 min/inch

Topography 2% Slope

Depth to Water Table [redacted] to 8' to lake level

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by F. J. Ervin

Plus 250 sq feet + 100' of drain line for washing machine Waste Water.

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: Bottom of Ditch for Septic Tank system is 3½' above lake level. Bottom of ditch for Washing machine drain is 2½' above lake level

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-14-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold