DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Katherine Weaver
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 3600 gpd DATE EVALUATED: 5-17-06
LOCATION OF SITE: _____ PROPERTY SIZE: 4.7-14-06
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	3% Back Yard	0-10	1sbk sl			48			.25
		10-24	1sbk scl						
		24-48	1sbk cl/cl	fr/fi ss/sp se					
2		0-8	1sbk sl		yellow/brown mottle	48			.25 .2
		8-25	1sbk scl						
		25-48	1sbk C	fr/fi ss/sp se					
3	4% front yard	0-8	1sbk sl			48			.25
		8-35	1sbk cl						
		35-45	1sbk C	fr ss/sp se					
		45-48	1sbk/gr sc	fi ss/sp se					
4		0-8	1gr sl			48			.25
		8-23	1sbk cl						
		23-34	1sbk C	fr ss/sp se					
		34-48	1sbk scl	fr					
			yellow/brown mottling						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	NO
System Type(s)	LPP Panel	exempt
Site LTAR	.25	

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): P3
EVALUATED BY: J. Melville
OTHER(S) PRESENT: _____

COMMENTS: _____