DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Terry Potter APPLICANT: Terry Potter
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 8-25-05
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: .462 AC
LOCATION OF SITE: 236 Elysian Dr PROPERTY RECORDED: 1968
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

6@44' ==
6@41' ==
seawall for lake

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	linear 9%	0-40	1sbk cl	fr ss/sp SE		48			
		40-48	1sbk c	fr ss/sp SE					.3
2	linear	0-34	1sbk cl	Cr ss/sp SE		42+			
		34-42+	1sbk c	fi ss/sp SE					
			hit stone						
3		0-42	1sbk cl	cr ss/sp SE		48			
		42-48	1sbk/abk c	cr ss/sp SE					.3
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Yes	partial
System Type(s)	conv	conv
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Judy Melville
OTHER(S) PRESENT: _____