4646-64-8942. 123
125

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bryant Hager DATE 1974 PERMIT NO. 159

PHONE: Business _____ Home _____

LOCATION US 21 South Cross I-77 TR _____ S. R. No. _____

SUBDIVISION NAME Hager Point Mobile Home Park LOT NO. 15+16 SECTION OR BLOCK NO. _____


Site Address: 123+125 Hager Point Ln - Mrsvl.

House ( ) Mobile Home ( ) Business ( ) Other 2 mobile Homes

No. Bedrooms 4 No. Bathrooms 4

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy clay loam Porous
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	30 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	30% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	None

Lot Area 1 acres



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1050 Linear Ft. _____
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public ( )

Installed by J.B. Poole

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 4-6-[illegible]

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold