4646-64-8942. 129, 131

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bryant Hager DATE 6-14-74 PERMIT NO. 160

PHONE: Business _____ Home _____

LOCATION US-21 South Cross J-27 T R at ent

S. R. No. _____

SUBDIVISION NAME Hager's Point mobile Home Park LOT NO. 8 SECTION OR BLOCK NO. _____

Site Address: 129 Hager Point Ln-Mrsul & 131 Hager Point Ln

House ( ) Mobile Home ( ) Business ( ) Other 2 mobile Homes

No. Bedrooms 4 No. Bathrooms 4

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____


Character & Porosity of Soil Sandy clay loam Porosity

Percolation Rate 30 min/inch

Topography 30% Slope

Depth to Water Table 10' ±

Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1000 Linear Ft. 200

Depth of Stone in Lines 18"

Water Supply: Individual ( )
Public ( )

Installed by J.R Bowles

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J.C. Moore DATE 6-14-

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold