4646-64-9592.137

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bryant Hager DATE 1974 PERMIT NO. 162

PHONE: Business _____ Home _____

LOCATION 115=1 South Cross I-77 TR at end

S. R. No. _____

SUBDIVISION NAME Hager's Point mobile Home Park LOT NO. 20 & 21 SECTION OR BLOCK NO. _____

Site Address: 137 Hager Point Ln - Mrsvl


House ( ) Mobile Home ( ) Business ( ) Other 2 Mobile Homes

No. Bedrooms 4 No. Bathrooms 4

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 6 acres

Character & Porosity of Soil Sandy Clay loam Perc Fair
Percolation Rate 30 min/inch
Topography 2% slope
Depth to Water Table 6+ ft
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. _____
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by J. R. Bowles

4

IMPROVEMENTS PERMIT BY L C Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L C Moore DATE 1-17-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold