4646-64-9592.137

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bryant Hagen DATE 6-20-79 PERMIT NO. 209

PHONE: Business _____ Home _____

LOCATION Hwy 21 S x I 77 T Ron 1206 near end on Left S. R. No. _____


SUBDIVISION NAME Hagers Ft. MH Park LOT NO. 20' SECTION OR BLOCK NO. _____

Site Address: 137 Hagen Point Ln. Mrsvl.

House ( ) / Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 min/in	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	sink.	
Lot Area Existing			Rock or other impervious formations	none obs.	



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10" +

Water Supply: Individual ( )
Public (✓)
Community Well

Installed by FJ ERVIN

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 6-20-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold