4646-64-9592.141

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bryant Hagar DATE 6-20-79 PERMIT NO. 210

PHONE: Business _____ Home _____

LOCATION Hwy 21S x I 77 IR on 1206 near end on left S. R. No. _____

SUBDIVISION NAME Hagers Pt. MH Park LOT NO. 22 SECTION OR BLOCK NO. _____


Site Address: 141 Hager Point Ln - Mrsul

House ( ) / Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area Existing

Character & Porosity of Soil Clay loam
Percolation Rate 30 mpi
Topography 2-4%
Depth to Water Table sink.
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"+
Water Supply: Individual ( )
Public (✓)
Community Well
Installed by F J Ervin

IMPROVEMENTS PERMIT BY David R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE 6-20-7

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold