4646-64-9592.141

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 6
(Ground Absorption Sewage Disposal System – G.S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hagers Point Mobile Park DATE 1-18-79 PERMIT NO. 20

PHONE: Business _____ Home _____

LOCATION 215 T R on 1206 Last Lot on Left before Lake

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 27 SECTION OR BLOCK NO. _____

Site Address: 141 Hager Point Ln. Mrsul.

House ( ) 2 Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 6 No. Bathrooms 4

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	60 min per	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	5% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6' to 8'	
			Rock or other impervious formations	None	


Lot Area Existing

Repair

Size of Tank Existing Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 360 Linear Ft. 120
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)



Plot of System

Installed by E.J. Ervin

IMPROVEMENTS PERMIT BY _____

COMMENTS: Put in all Line that could put in

CERTIFICATE OF COMPLETION BY John Houston DATE 1-18-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold