1

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Center Presbyterian Church Parsonage DATE 11-9-82 PERMIT NO. 358

PHONE: Business _____ Home _____

LOCATION Hwy 21 S. TC 1247 TC 1245 50' on Rt.

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes	(✓)	No	( )	Character & Porosity of Soil Clay Loam
Auto. Dishwasher	Yes	(✓)	No	( )	Percolation Rate 2-5 Min/Inch
Auto. Wash. Machine	Yes	(✓)	No	( )	Topography 2-4%
Site Suitable	Yes	(✓)	No	( )	Depth to Water Table UNK.
					Rock or other impervious formations NONE OBS.

Lot Area Existing

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank Existing Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 960 Linear Ft. 320

Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by F.J. Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: New tee set in tank

CERTIFICATE OF COMPLETION BY David R. Hyman DATE 11-9-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold