11983

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Centre Presbyterian Scout Hut DATE 9/14/90 PERMIT NO. 2H-B-17

PHONE: Business _____ Home _____

LOCATION Behind Centre Presbyterian Church on Centre Church Rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Scout Hut Bld size ~ 36' x 60' ~25 Boy Scouts ~100 cub scouts Mtg ~ 5hrs/week

No. Bedrooms — No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No (✓)	
Site ~~Suitable~~ PS	Yes (✓)	No ( )	

Character & Porosity of Soil PS clay

Percolation Rate .4

Topography 1-5%

Depth to Water Table +3'

Rock or other impervious formations none obs.


Lot Area _____

Designed ~ 250 gpd 10 gal/person/day

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900' Linear Ft. 300'
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )



Plot of System

Installed by Petty & Allison

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Sam Ingram EHS

COMMENTS:

* Area of drainfield must be blocked off to prevent vehicles from driving or parking over system.

Drive

Parking Area

50'

X Well

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold