DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Rick Knight 892-7393 APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: 1/10/96 DATE EVALUATED: ___
PROPOSED FACILITY: 2BD - 1BA PROPOSED DESIGN FLOW (.1949): 240GAL PROPERTY SIZE: ___
LOCATION OF SITE: 215TR Waterlyn on (R) in field past Regal Dr. PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941): .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS: .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ	PROFILE CLASS & LTAR
1		0 - 8	sbK / scl						
		9 - 19	sbK / c	FI S SP					
		26 - 36	sbK / cl	FR SS SP					
		37 - 47	GR / sicl	FR S SP				.35	
2		0 - 6	sbK / cl	FI SS SP					
		7 - 30	whsbK / c	FI S P					
		31 - 48	GR / cl	FR S SP				.35	
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	CONV	INF
Site LTAR	.35	

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___

240 ÷ .35 = 685
685 ÷ 3 = 230
230 ÷ 3 = 76.1