v 4646-85-9819

9819

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Smith Builders DATE 6-13-97 PERMIT NO. 149

PHONE: Business _____ Home _____

LOCATION 215 From 1235

S. R. No. _____

SUBDIVISION NAME Regal Park LOT NO. 8 SECTION OR BLOCK NO. _____

Site Address: 180 Regal Circle - Mooresville

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 Acre


Character & Porosity of Soil Sandy Clay loam Fair to Good

Percolation Rate 50 / 60 mins

Topography 2 to 5%

Depth to Water Table 10' +

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Well not shown

Installed by [illegible]

Septic Tank

IMPROVEMENTS PERMIT BY [signature]

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 6-23-97

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold