4646-86-8092 V

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard Murphy DATE 10-21-01 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION US 21 South TR on 1155

S. R. No. _____

SUBDIVISION NAME Regal Oaks LOT NO. 9 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 acre


Character & Porosity of Soil Sandy clay loam friable

Percolation Rate Soil Loving 55

Topography 2% Slope

Depth to Water Table 10'+

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

Ditch
12"x20" 3 lines

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Locate well minimal house 100' from any part of Septic Tank System

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-21-01

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold