4644-86-9246

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas Ivester DATE 8-11-76 PERMIT NO. 213

PHONE: Business _____ Home _____

LOCATION US 21 South TR on 1135

S. R. No. _____

SUBDIVISION NAME Regal Oaks LOT NO. 11 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

(Porosity good)

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area ½ acre


Character & Porosity of Soil Sandy Parent material

Percolation Rate Soil borings

Topography 2% Slope

Depth to Water Table 10'+

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

2 Nitrification Field:

No. of Lines 2 lines in each

Sq. Ft. 630 Linear Ft. 250

Depth of Stone in Lines 18"

Water Supply: Individual (✓)

Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-11-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold