SUMMARY

This site is **PROVISIONALLY SUITABLE** for a ground absorption wastewater treatment and disposal system under current laws and rules 15A NCAC 18A .1900.

Conventional systems	NO
Shallow conventional systems	YES
Large Diameter Pipe systems	YES
Prefabricated Porous Block Panel systems	NO
Low Pressure Pipe Systems	MAYBE
Fill Systems	NO
Aerobic Treatment Systems	NO

This report gives a brief summary of the findings, conclusions, and recommendations.

If you have any questions or I can be of assistance contact me at the Mooresville Regional Office (704) 663-1699.

INTRODUCTION

COUNTY: Iredell

OWNER/APPLICANT: Winfred Bridges

LOCATION: Clippers Run, lot #11

TYPE OF FACILITY: Residence

DESIGN UNIT: 360 gpd

PROPOSED WATER SUPPLY: On-site well

EVALUATED BY: Joe Lynn assisted by Andrea Lemmon, Steve Hedrick, David Hinson, using back hoe pits

DATE OF EVALUATION: August 20, 1993

OTHER(S) PRESENT: N/A

SITE INFORMATION

AREA/PRESENT USE: Approximately 4,000 sq. ft. / grass

TOPOGRAPHY: 2 to 5 percent