970

4646931676

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Melvin Shumake DATE 8/14/89 PERMIT NO. 2H-B-9

PHONE: Business _____ Home _____

LOCATION 2 1 S. of Mooresville On R. just past jct. w/ Waterlynn Rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	.35 gpd/ft²
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-10%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none obs

Lot Area _____

___ Basement with Plumbing ✓ Will accommodate future basement plumbing ___ Basement without Plumbing ___ No Basement



Plot of System Not To Scale

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 705 Linear Ft. 235
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Mike Lyons

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andre C Rene

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andre C Rene, RS DATE 8/15/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold