2.30

4646965968

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mark Kyotis DATE 12-6-78 PERMIT NO. 291

PHONE: Business _____ Home _____

LOCATION 21 S Below Golf Course

_____ S. R. No. _____


SUBDIVISION NAME Huntington Woods LOT NO. 6 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min/in
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	15% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10 ft
			Rock or other impervious formations	none

Lot Area ½ ac



Plot of System

split System
upper

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Lower System
800 gal Tank
100' 3" PVC Pipe

Installed by J.R. Bowles

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Hamilton DATE 12-6-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold