4646973102

IREDELL COUNTY HEALTH DEPARTMENT

Mooresville office

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Don Gabriel DATE 8-26-99 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION US 21 South TR after cross Jane Norman S. R. No. _____

SUBDIVISION NAME Hunting Woods LOT NO. 8 SECTION OR BLOCK NO. _____

Site Address: 179 Huntington Ln. Mrsvl

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 40 acres


Character & Porosity of Soil Clay + sandy rocky mix

Percolation Rate 45m/inch

Topography 25% slope

Depth to Water Table 10'+

Rock or other impervious formations some sandy rock + sand stone



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 24"

Water Supply: Individual (✓)

Public ( )

Installed by J. R. Powell

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-26-99

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold