4646974045

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Raymond E. Hobbs DATE 4-22-80 PERMIT NO. 94

PHONE: Business _____ Home _____

LOCATION 215 TR Huntington Woods Lot on left

_____ S. R. No. _____

SUBDIVISION NAME Huntington Woods LOT NO. 7 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)

Auto. Dishwasher Yes ( ) No (X)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre +


Character & Porosity of Soil Clay loam

Percolation Rate 30 Min +

Topography 6-10%

Depth to Water Table unknown

Rock or other impervious formations NONE observed



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 250 Linear Ft. 250

Depth of Stone in Lines 16"

Water Supply: Individual (X)

Public ( )

Installed by T. J. Erwin

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 4-22-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold