11814

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

4646-97-4278

OWNER OR CONTRACTOR Terry Wilson DATE 10/3/91 PERMIT NO. 2J-9-A-12

PHONE: Business _____ Home _____

LOCATION 215 TR into Huntington Woods, to end of road on (R) next to last house on lake side S. R. No. _____

SUBDIVISION NAME Huntington Woods LOT NO. 12 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil P - c - sic (s - sf)
Percolation Rate .3
Topography 10 - 15%
Depth to Water Table > 48"
Rock or other impervious formations firm at 36" / wk sbk

Lot Area 20,000 FT²

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement



Size of Tank 1000 - PT / 1000 - ST Gals.

Nitrification Field:
No. of Lines 3 @ 67' x 21
Sq. Ft. _____ Linear Ft. 200
Depth of ~~Stone~~ SAND in Lines 6" bottom

Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: 3/16" holes, 1 per panel drilled on site - alarm checked - alarm to be mounted inside the house

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 10/3/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold