106 Pond Heaven

IREDELL COUNTY HEALTH DEPARTMENT 4647-00-0072

14296

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR William Rotteck DATE 9/30/92 PERMIT NO. 2K-19-A-3

PHONE: Business 636-7954 Home

LOCATION 11.0 mi, TL into Farmstead Rd, on (R) at intersection of 2nd road on the (R), lot on (R) corner S.R. No.

SUBDIVISION NAME Farmstead Estates LOT NO. 32 SECTION OR BLOCK NO.

House ☑ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area ~ 1 Ac

Soil Characteristics P


Application Rate P - .35 (wk 55 sf)

Topography P - 2%

Depth to Water Table 5 > 48"

Rock or other impervious formations 5 None observed

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4 @ 115 x 3'

Sq. Ft. 1028 Linear Ft. 330

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Well

80' to Close to Bdry

Installed by Rowan Septic Tank

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed:

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY

COMMENTS

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 9/30/92

EXISTING SYSTEM CHECKED BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold