DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: John Brown [redacted] Brightstar Dev. OWNER: ✓ AGENT: ___ PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 7/20/94
PROPOSED FACILITY: Dental Office
PROPERTY SIZE: ___
LOCATION OF SITE: 1100 on left ~ 1/4-1/2 mile past Brandy School
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓

PROFILE /	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	LS-SS ~4%	0-8"	gr- scl	1:1 / fr					.5
		8-34	SAB- c	1:1 / fi-vfi					.4
		34-46+	wkSAB- scl	1:1 / fi-vfi					.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945) ___ SITE CLASSIFICATION (.1948): ___ SITE LONG-TERM ACCEPTANCE RATE ___
EVALUATED BY ___ OTHER(S) PRESENT: ___
COMMENTS: ___

Existing Structure 38'X28' = 1064 ft²
Ex Well ~ 44' from Ex Bld foundation

7-18-94 According to Steven Berkowitz Design flow should be figured @ 480 gal/1000 ft² building space + 25/gal per employee + 5 gal/patient

(over)