4647100407

IREDELL COUNTY HEALTH DEPARTMENT

10841

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jay Youngblood DATE March 16, '90 PERMIT NO. 2K-16-A-S

PHONE: Business _____ Home _____

LOCATION 1/10 past Brawley School TL just past Duke Power Substation onto Charleston Dr. at end on Right S. R. No. _____

SUBDIVISION NAME Williamsburg Estates LOT NO. 8 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable PS	Yes	(✓)	No	( )	

Lot Area 20000ft²

Character & Porosity of Soil PS clay
Percolation Rate MPI 35
Topography rolling
Depth to Water Table 4'+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1050 Linear Ft. 350
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Orbison

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY O R Hanson, EHS DATE 3-16-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold