DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED:
COUNTY: Iredell


SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Chris Stenger OWNER: AGENT: PHONE:
ADDRESS: Lot 4 Front Lead APPLICATION DATE: DATE EVALUATED: 5/6/96
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring Pit ✓ Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	Backhoe pits
1	3%	0-6	SCL	Gr	Fri SS,SP	.1942 WETNES CONDITION -
		6-16	C	SBK	FI S,P	.1943/.1956 SAPROLITE -
		16-40	CL	WSBK	FRI SS,SP	.1944 RESTRICTIVE HORIZON - 42"
		40+	Sap.	Weathered Rock		.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3 gpd/ft
2	3%	0-4	SCL	Gr	Fri SS,SP	.1942 WETNES CONDITION -
		4-16	C	SBK	FI S,P	.1943/.1956 SAPROLITE -
		16-36	CL	WSBK	FRI SS,SP	.1944 RESTRICTIVE HORIZON -
		36+	Sap. - Weathered Rock		SS,SP	.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3	3%	0-14	C	SBK	FI SS,SP	.1942 WETNESS CONDITION -
		14-24	CL	WSBK	FRI SS,SP	.1943/.1956 SAPROLITE -
		24-36	C-Sap	WSBK	FRI SS,SP	.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
4	3%	0-6	C	SBK	FI SS,SP	.1942 WETNESS CONDITION -
		6-48	C-Sap	W-Rock		.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON - 4
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE:
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: OTHER(S) PRESENT:
COMMENTS:

DRAFT


4BR
Move
house 30'
Chanbered
PS
PS
Drive
RS 5x80's
Repair