4647-70-3384

13408

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Brelin DATE 9/17/91 PERMIT NO. 2T-16-A-4

PHONE: Business _____ Home 664-2766

LOCATION Kitty Hawk Dr. 2nd TR Brawley Sch Rd, TL on Gibbs Rd, TR Kitty Hawk TR to cul de sac, Lot on (L) half of cul de sac S. R. No. _____

SUBDIVISION NAME Newport Village LOT NO. 4 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Mechanic

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 AC.

Character & Porosity of Soil P - C - trans. cl


Percolation Rate .25 ~~.35~~ (B - V cobbly)

Topography 3-4% ~~7%~~

Depth to Water Table >48"

Rock or other impervious formations Cobbly - trans. material

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4 @ 120' x 3'

Sq. Ft. 1440 Linear Ft. 480

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Robert J. Brelin

IMPROVEMENTS PERMIT BY Wesley Sparks R.S.

COMMENTS: Trenches no deeper than 30" to trench bottom. Lines must follow slope contour in direction shown. Drop boxes are to be used on this system.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold