4647-70-7133

IREDELL COUNTY HEALTH DEPARTMENT

11294

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sui Fan Jang DATE Jun 26, 1990 PERMIT NO. ST-16-A-2

PHONE: Business _____ Home _____

LOCATION 215 TR 1100 TL Gibbs, ¼ mi TR Kitty Hawk

_____ S. R. No. _____

SUBDIVISION NAME Newport Village LOT NO. 2 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	N .35 gpd/sft
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	5-10%
Site ~~Suitable~~ PS	Yes (✓)	No ( )	Depth to Water Table	+ 3'
			Rock or other impervious formations	none obs.

Lot Area 20,000

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines _____

Water Supply: Individual (✓)
Public ( )

Installed by Bob MacCleod

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Well not installed at time of this final.

CERTIFICATE OF COMPLETION BY Sam Ingram EHS DATE 6/26/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

11:30

11294

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sui Fan Tang DATE April 3, 1990 PERMIT NO. 2T-16-A-2

PHONE: Business _____ Home _____

LOCATION 21 S TR 1100 TL Gibbs, ¼ mi TR Kitty Hawk

S. R. No. _____

SUBDIVISION NAME Newport Village LOT NO. 2 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ PS Yes ( ) No ( )

Lot Area 20,000

Character & Porosity of Soil clay


Percolation Rate ~.35 gpd/ft²

Topography 5-10% slope

Depth to Water Table +3'

Rock or other impervious formations none obs.

Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed _____

IMPROVEMENTS PERMIT BY Sam Ingram REHS

COMMENTS: Front of house presently 65' from road bank. If front can be moved farther back it could be possible to have 100% conventional gravity flow repair.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold