14043

IREDELL COUNTY HEALTH DEPARTMENT

PIN# 4647-80-8812

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Eric Klengel DATE 6/23/92 PERMIT NO. 2I-11-A-2

PHONE: Business _____ Home _____

LOCATION 21 S TR 1100 (Brumley Sch Rd) TL Sanfish Dr. to corner lot on (R)

S.R. No. _____

SUBDIVISION NAME Clippers Run LOT NO. 2 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2.5 Soil Characteristics P - C


Garbage Disposal Unit Yes ☑ No ☐ Application Rate P ~ .4

Auto. Dishwasher Yes ☑ No ☐ Topography P ~ 2%

Auto. Wash. Machine Yes ☑ No ☐ Depth to Water Table 5' >48"

Lot Area ~1.5AC Rock or other impervious formations 5 - None observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 4 @ 150' x 3'

Sq. Ft. 1800 Linear Ft. 600

Depth of Stone in Lines 12"

Water Supply: Individual ☑ NOT DRILLED YET. Public ☐

Installed by Andy Jones

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY _____

COMMENTS _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS, DATE 6/23/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold