IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tyrone Stoner DATE 6-13-85 PERMIT NO. 266

PHONE: Business _____ Home _____

LOCATION 21 North to 1305 to 2nd Drive 3rd on left

S. R. No. _____

SUBDIVISION NAME Scarlet Oaks Mobile Park LOT NO. 18 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Existing
Site Suitable	Yes (X)	No ( )	Depth to Water Table	
			Rock or other impervious formations	System

Lot Area Existing

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank Existing Gals.

Nitrification Field:
No. of Lines Existing
Sq. Ft. _____ Linear Ft _____
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public (X)

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Existing System working OK at date of inspection

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Fred Clemmer DATE 6-13-85

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tyrone Stoner DATE 3-30-82 PERMIT NO. 66

PHONE: Business _____ Home _____

LOCATION 21 North to 1305 Near end TR Scarlet Oaks MH Park on left _____ S. R. No. _____


SUBDIVISION NAME Scarlet Oaks MH Park LOT NO. 18 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	2-10 Gpf	
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Unknown	
Site Suitable	Yes (X)	No ( )	Depth to Water Table	None observed	
Lot Area 15,000 ft²			Rock or other impervious formations		

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual _____
Public (X) Community H2O

Installed by J. C's Backhoe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY O R Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 3-30-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

330

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tyrone Stover DATE Jan. 5, 1980 PERMIT NO. 40

PHONE: Business _____ Home _____

LOCATION Hwy 21 N Tl on 1305 ~ 1 mi on Rt.

SUBDIVISION NAME Scarlet Oaks M.H. Park LOT NO. 18 SECTION OR BLOCK NO. _____ S. R. No. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 15,000 ft² +

Character & Porosity of Soil clay loam
Percolation Rate 30 min
Topography 6-8%
Depth to Water Table unk.
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)
Community Well

Installed by _____

IMPROVEMENTS PERMIT BY Harold R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold