4648007822

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Billy Phillips DATE 3-10-80 PERMIT NO. 44

PHONE: Business _____ Home _____

LOCATION 150W TRon 1304 on Rt. in curve

S. R. No. _____

SUBDIVISION NAME Lynnbrook Acres LOT NO. 1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ~½ AC.


Character & Porosity of Soil clay loam

Percolation Rate Slows 2-4 for 4

Topography _____

Depth to Water Table _____

Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 250

Depth of Stone in Lines 16"

Water Supply: Individual (✓)

Public ( )

Installed by J. J. Erwin

IMPROVEMENTS PERMIT BY [illegible]

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Mark R. Hinson DATE 3-10-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold