IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wade Cook DATE 10-11-73 PERMIT NO. 297

PHONE: Business 523-0312 Home 782-8454

LOCATION US 21 By-Pass Turn on 1302 Cross I-77 Tl on 1395 stay right on 1395 Tl at end .3 mi+ S.R. No.

SUBDIVISION NAME Duke Power LOT NO. 38 SECTION OR BLOCK NO. 12


House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Sandy clay loam
Percolation Rate not taken
Topography 3% to 5% slope
Depth to Water Table 10'+
Rock or other impervious formations 5' to 15' to bedrock

Lot Area 3/4 acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 18"
Water Supply: Individual (✓)
(Proposed) Public ( )

Installed by E. J. Ervin

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Plans to use neighbor's well

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 11-19-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold