IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wade Cook DATE 8-3-76 PERMIT NO. _____

PHONE: Business 528-0212 Home 782-5454

LOCATION US 21 By-Pass Turn on 1302 cross I-77 Turn L on 1395 stay right on 1395. Turn R at end 3 mi on left S. R. No. _____


SUBDIVISION NAME Duke Power LOT NO. 38 SECTION OR BLOCK NO. 12

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Existing
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	System

Lot Area 3 Acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 562 Linear Ft. 225
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by F. J. Irvin
10-11-73

IMPROVEMENTS PERMIT BY _____

COMMENTS: System is adequate for proposed house

CERTIFICATE OF COMPLETION BY A. C. Moore DATE 8-3-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold