4648036588

IREDELL COUNTY HEALTH DEPARTMENT

(S[illegible]TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
[illegible]nd Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CO[illegible] G. W. Randall DATE 6-24-96 PERMIT NO. 168

PHONE: Bus[illegible] Home 379-7634

LOCATION 1275 TR on 1422 4m. on left

S. R. No.

SUBD[illegible] NAME Lake Norman LOT NO. 40 SECTION OR BLOCK NO. 12

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 2 acre


Character & Porosity of Soil Clay loam porosity F[illegible]

Percolation Rate soil [illegible]

Topography 25% slope

Depth to Water Table 6+ft to Lake Level

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2 in parallel

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 18"

Water Supply: Individual (✓)

Public ( )

3'x50' Washer drain 5'x10' 1 line

Installed by Howard Wyatt (Contractor)

IMPROVEMENTS PERMIT BY [illegible]

COMMENTS:

CERTIFICATE OF COMPLETION BY [illegible] DATE 6-26-96

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold