4644806925D

IREDELL COUNTY HEALTH DEPARTMENT

ENTERED

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Henry A. Hanzlik DATE 11-6-75 PERMIT NO. 252

PHONE: Business _____ Home _____

LOCATION 21 North TL 1302 : TL on 1440 at end TL S. R. No. _____

SUBDIVISION NAME Pirates Cove LOT NO. 11 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 100 x 200'

Character & Porosity of Soil Clay Porosity Fair
Percolation Rate not Taken
Topography 2 pt 3% Slope
Depth to Water Table 10 ft
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Clontz Backhoe

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 11-6-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold