DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: James MacIntosh APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6/23/04
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .50
LOCATION OF SITE: Lot 10 Pirates Cove PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	5-7%	0-8	sbk / l	Fi ss - sp	/ BP				
		9-24	fri sbk / cl	Fr. ss-sp	PS / 4R				
		25-41	fr fr sbk / l SAP	Fr ss - sp	PS / CH 3 4R				
		42-49	VFR Fr wk sbk / SAP	FR ss - NP	PS / 4R				
2	7% NCC	0-5	ak-sbk / c	Fi s - sp	PS / 2R Few 1				
		6-26	sbk / cl	Fr ss - sp	PS / CH 3		PS		
		27-48	sbk w sg l SAP	FR ss - NP	PS / 4R INCL				
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	<83
System Type(s)	Typ 3	
Site LTAR	.35	

OTHER FACTORS (.1946): H @ 90' x 3'
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____