IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 072387 DATE 3/27/98

OWNER OR CONTRACTOR Harold Perkins TAX MAP NO. 4648 07 7345

ADDRESS 1772 N Hwy 16 Denver, NC, 28037 PHONE: Business _____ Home 483-5149

LOCATION Cornelius Rd on (L) just past Morgan Bluff Ln. Watershed: ☑ Yes ☐ No

SUBDIVISION N/A BLOCK / SECTION _____ LOT _____ LOT AREA 1.17 SITE CLASS. PS DESIGN FLOW 240 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1012 Date 1/22/98

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field; No Fields 1 Square Feet 900 Linear Feet 300

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: 2ST BOX - CONVENTIONAL

Repair System Description: SAME

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod Home No. Bedrooms 2

☐ Mobile Home No. Bathrooms 2

☐ Business No. Employees _____

☐ Other _____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Community ☐ Public

Comments:

Comments: Drop Boxes used

INITIAL SITE SKETCH



AS BUILT SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed: X Harold Perkins

Improvement Permit by: Wesley Sparks RS. date 3/27/98

Existing System Inspection by: Wesley Sparks RS. date 3/27/98

Installed by: A1 Backhoe

Certificate of Completion by: Wesley Sparks RS. date 4/2/98

Operation Permit by: _____ date _____

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD