IREDELL COUNTY HEALTH DEPARTMENT 4648102862

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fred Ziegler DATE 5-4-84 PERMIT NO. 122

PHONE: Business _____ Home _____

LOCATION 150W TR 1304 TR 1470 3rd lot on left

S. R. No. _____

SUBDIVISION NAME Lynnbrook Acres LOT NO. 6 SECTION OR BLOCK NO. _____


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	
Auto. Dishwasher	Yes (X)	No ( )	
Auto. Wash. Machine	Yes (X)	No ( )	
Site Suitable	Yes (X)	No ( )	

Lot Area ~20,000 ft²

Character & Porosity of Soil Clay loam / Friable
Percolation Rate 0.5 gal/ft²/day
Topography 15-25% slope
Depth to Water Table 4 ft
Rock or other impervious formations None obs.



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines (2) X 2
Sq. Ft. 1080 Linear Ft. 360
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by J. J. Erwin Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY FK

COMMENTS: Relayout

CERTIFICATE OF COMPLETION BY Fred Zimmer DATE 5-4-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold