es 410.00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 144315 PIN# 4648104810.000 DATE 6/17/08

OWNER OR APPLICANT Joe Swift PHONE: Business 954 817 9529 Home

ADDRESS 2825 Southwest 132 Way Davie, Fl

LOCATION Hwy 150 N TR Erwin Rd TR Lynbrook 3rd Lot on Left

SUBDIVISION Lynbrook BLOCK / SECTION LOT 8 LOT AREA .48 ac SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .4

Septic Tank: 1000 Gallons; STB 794 Date 8-11-09
Pump Tank: 1000 Gallons; PT 283 Date 5-15-09
Pump Make: GOULDS Model WE05111H Serial No. ½ HP
Nitrification Field: No Fields 1 Square Feet 300 Linear Feet 150'
No Lines 3 Trench Width 24 or 36" Max Trench Bottom Depth 36"

☑ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI
System Description: LPPPBPS
Repair System Description: same
Maintenance Agreement Required: ☐ Yes ☐ No


☑ House/Mod. Home No. Bedrooms 3
☐ Mobile Home No. Persons
☐ Business No. Employees
☐ Other


Water Supply: ☑ Individual ☐ Public ☐ Community

Gravel Depth N/A ☐ Gravity ☑ Pressure ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Lake ~ 43,55,55 line lengths

Comments/Conditions: Keep System min 100' from well Exs. + 50' well separation from septic tanks





Plans reviewed 1st floor bath must be ½ bath and second floor study room must have closed opening per signed plans by Robert Sherrill

Must be checked 6/18/08 AC for OP.

CHECKED TANKS + PUMP 12-4-09

12/8/09 24# pressure set MD

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Robert Sherrill date 6-16-08 Installed by: C. Wayne Orbison RS

Improvement Permit by: Anthony Cobert date 6/17/08 Operation Permit by: date 2/18/2010

Authorization to Construct by: Anthony Cobert date 6/17/08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK