4648 10 6823 6494

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jim Hartness DATE 10-21-15 PERMIT NO. 243

PHONE: Business _____ Home 292-3402

LOCATION 15 west TR on Stutts Rd. TR 1st hard crook sch 1st

SUBDIVISION NAME Lynnbrook LOT NO. 12 S. R. No. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other Existing House Started 9-4-13

No. Bedrooms 5 No. Bathrooms 3

Garbage Disposal Unit	Yes	( )	No	( )	
Auto. Dishwasher	Yes	( )	No	( )	
Auto. Wash. Machine	Yes	( )	No	( )	
Site Suitable	Yes	( )	No	( )	

Lot Area 1.5 acres

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate 21 min 1 ft
Topography Rolling slope
Depth to Water Table 10 ft
Rock or other impervious formations None



Plot of System

Size of Tank 1000 gal Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1250 Linear Ft. 700
Depth of Stone in Lines 24"
Water Supply: Individual ( )
Public ( )

Installed by Gladius Marcus Huntersville, N.C.

IMPROVEMENTS PERMIT BY J. C. Mercer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Mercer DATE 12-3-15

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold