IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR B.M. Hastings DATE 10-31-75 PERMIT NO. 243

PHONE: Business _____ Home 892-4006

LOCATION 15c West TR on Stutts Rd. TR at bend 1000' on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Existing House Started 9-4-13

No. Bedrooms 5 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area ½ acre

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate Not taken
Topography 2% Slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

2 Tanks 1000 gal
Size of Tank 2000 gal Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 20"

Water Supply: Individual (✓)
Public ( )

Installed by Cladius Morrison
Huntersville, N.C.

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-31-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold