4648 10 6536

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dr. Chong H. Lieu DATE 8-26-86 PERMIT NO. 470

PHONE: Business _____ Home _____

LOCATION 150 W TR Ervin Rd. (1304) TR Lynnbrook ~1/4 mile on left 131 Lynnbrook Rd S. R. No. _____

SUBDIVISION NAME Lynnbrook Acres LOT NO. 11 (112) SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other upgrading system to 4 bedroom capacity


No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil clay
Percolation Rate 4, 5
Topography 2-6%
Depth to Water Table 41+
Rock or other impervious formations none obs.

Lot Area ~1/2 Ac.

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Addition to Ex. system

Size of Tank _____ Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 225 Linear Ft. 75'
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by J J Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J C Moore

COMMENTS: Only able to get 75 linear feet installed. JCM

CERTIFICATE OF COMPLETION BY James R. Hunnicutt, R.S. DATE 8-26-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold